

IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 – USA • 909-472-4100 • 909-472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

The most updated information on this Certificate of Listing is available online at pld.iapmo.org

Effective Date: June 2017

Void After: June 2018

Product: PVC Plastic Pipe (Sch. 40, 80, 120)

File No. 7845

Issued To: Plastic Services & Products, Llc.
1760 W. 1900 S. #1
Salt Lake City, UT 84104

Identification: Marking on the pipe shall include the following at intervals of not more than 5ft. Nominal pipe size , type of plastic pipe material , schedule, pressure rating in psi for water at 73°F, ASTM D1785, Manufacturing name or trademark, name of laboratory making evaluation for pipes transporting potable water and the UPC® certification mark.

Characteristics: A plain or bell end solvent cemented or elastomeric gasketed rigid polyvinyl chloride (PVC) pipe to be installed in accordance with the requirements of the latest editions of and the Uniform Plumbing Code. USE IS LIMITED TO COLD WATER SERVICE AND YARD PIPING.

Bell end gasketed pipe to be installed with assemblies fabricated with IAPMO listed fittings and compatible pressure rated pipe stubs. Plain or bell end solvent cemented pipe to be used with IAPMO listed PVC fittings, primers and solvent cements.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the


Chairman, Product Certification Committee


CEO, The IAPMO Group



This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.



IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Page 2

Void After: June 2018

Product: PVC Plastic Pipe (Sch. 40, 80, 120)

File No. 7845

Issued To: Plastic Services & Products, Llc.

laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)

International Plumbing Code (IPC®)

Products are in compliance with the following standard(s):

ASTM D1785-2015

NSF/ANSI 14-2016a



IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Page 3

Void After: June 2018

Product: PVC Plastic Pipe (Sch. 40, 80, 120)

File No. 7845

Issued To: Plastic Services & Products, Llc.

MODELS:

Model No.

P40-1
P40-12
P40-34
P40-12
P40-114
P40-112
P40-2
P40-212
P40-3
P40-4
P40-6
P80-12
P80-34
P80-1
P80-114
P80-112
P80-2
P80-212
P80-3
P80-4
P40-12PE
P40-34PE
P40-1PE
P40-114PE
P40-112PE
P40-2PE
P40-212PE
P40-3PE
P40-4PE